

FIRE DEPARTMENT

To: Adrienne Senter

From: Brian Eskew, Fire Marshal

Re: Hapeville Library 525 King Arnold

Date: March 25, 2019

I have completed my review of this project and have found the following items to be corrected:

- 1) Parking lot needs to be connected at lower driveway and upper driveway.
- 2) If Building is going to be sprinklered FDC location must be shown.

If you should you should need any questions please let me know. Thanks.